



Well Flowmeter Accuracy Testing Form

PO Box 225 – Carpinteria, CA 93014

The Agency's Well Registration and Metering Policy (Policy) requires that meters remain within an accuracy range of $\pm 5\%$. Brand new flowmeters installed after Policy adoption must be tested for accuracy after 5 years and then every 3 years thereafter. Flowmeters that were not brand new after Policy adoption must demonstrate their accuracy initially and then through meter accuracy testing every 3 years thereafter. Flow testing shall represent typical flows from the well.

State Well Number: _____

Assessor Parcel No. (APN): _____

Parcel Address: _____

Owner: _____

Customer Meter Information		
Meter Manufacturer	Meter Model #	Meter Serial Number
Meter Units of Measure ☐ AF ☐ CF ☐ Gal ☐ Other:	Meter Multiplier	
Meter Use ☐ Agricultural ☐ Domestic ☐ Municipal/Industrial	Meter Size (inches)	Discharge Pipe Size (inches)
Pipe Material	Pipe Inside Diameter Used for Calculation	

Control Meter Information	
Test Instrument(s) Used in the Flowmeter Accuracy Test	Control Meter Units of Measure ☐ AF ☐ CF ☐ Gal ☐ Other:

Calibration Test Results for In-Place Flowmeter Testing (Three distinct tests for a minimum of 5 minutes each. Stop the flow between tests)

		End Meter Reading	Start Meter Reading	Volume Pumped	Units	Run Time (mins)	Flow rate (gpm)	Accuracy (%) [*] see page 2
1	Customer				Units			
	Control				Units			
2	Customer				Units			
	Control				Units			
3	Customer				Units			
	Control				Units			

Flowmeter Accuracy Testing Contractor: Is the Owner's meter within a range of $\pm 5\%$ compared to the control meter for all three test segments? ☐ **YES/PASS** ☐ **NO/FAIL**

Remarks: _____

Calibration Contractor/Vendor: _____

Technician Name: _____ Date of Test: _____ Time: _____

***The Flowmeter Accuracy Testing Contractor must attach or staple proof of their instrument's calibration* ¹**



CARPINTERIA GSA
GROUNDWATER SUSTAINABILITY AGENCY

Well Flowmeter Accuracy Testing Form

PO Box 225 – Carpinteria, CA 93014

How to Calculate the Accuracy Column

Formula:

$$\frac{\text{Control Meter Volume} - \text{Customer Meter Volume}}{(\text{Control Meter Volume} + \text{Customer Meter Volume}) / 2} \times 100 = \text{percentage (\%)}$$

Use this formula for consistency across reporting. This formula acknowledges that there may be some uncertainty in the control meter reading & therefore uses the average of the control meter reading and customer meter reading as the denominator.